



Article title: Airborne bacterial species in indoor air and association with physical factors

Authors: Anne Mette Madsen[1], Salomeh Moslehi-Jenabian[2], Mika Frankel[3], John Ker White[4], Margit W. Frederiksen[5]

Affiliations: national research centre for the working environment, lersø parkallé 105, 2100 copenhagen ø, denmark[1], division of clinical microbiology, karolinska university hospital, stockholm, sweden[2]

Orcid ids: 0000-0002-5895-7521[1], 0000-0003-3485-5958[4], 0000-0001-7184-1171[5]

Contact e-mail: amm@nrcwe.dk

License information: This is an open access article distributed under the terms of the Creative Commons Attribution License (CC BY) 4.0 <https://creativecommons.org/licenses/by/4.0/>, which permits unrestricted use, distribution and reproduction in any medium, provided the original author and source are credited.

Preprint statement: This article is a preprint and has not been peer-reviewed, under consideration and submitted to UCL Open: Environment Preprint for open peer review.

Funder(s):Funder(s):||Funder(s): Grundejernes Investeringsfund

DOI: 10.14324/111.444/000195.v1

Preprint first posted online: 30 January 2023

Keywords: Bacillus megaterium, bacteria, exposure, home environment, indoor air, indoor humidity, MALDI-TOF MS, Paracoccus yeei, room-to-room variation, seasonality, Built environment, Health

We hereby want to submit the paper: Airborne bacterial species in indoor air and association with physical factors. The study was presented at ICMB21, and is supposed to be part of the special issue for ICMB21.

Background information about bacteria: Bacteria are divided into many different genera, and these genera are divided into many different species. One species in a genus can be a pathogen while another species within the same genus can be beneficial for humans. Some species are well-known human pathogens, others are described as emerging pathogens, and most species are not pathogens but may cause inflammation. Therefore, knowledge about which bacterial species are present in indoor air and which factors have an impact on this is important.

The contribution of this study: We have identified airborne bacteria down to species level in 52 Danish homes. Many bacterial species were present, and of these species, 11 were present in several homes. Some of the found species are classified as pathogens e.g. *Paracoccus yeei* which can cause eye infection and *Bacillus cereus* which is a food-poisoning agent. Some species can cause disease in persons with a weakened immune system, e.g. *Moraxella osloensis* and *Rhizobium radiobacter*. Some species are emerging human pathogens, and other normal skin bacteria.

We found a room-to-room variation in concentrations of bacteria, but an overlap in bacterial species across rooms within a home. The bacterial species composition varied between seasons. The concentrations of some bacterial species were highest when the air change rate was lowest and in homes with the smallest area per occupant. Concentrations of some species were highest when the relative humidity was highest.

We conclude that, across homes and room types within homes, occupants are exposed to some of the same cultivable bacterial species, and decreasing the relative humidity, and increasing the air change rate and area per occupant may be a strategy to reduce the exposure to some bacterial species.

Relation to previously published work: Previously focus has mainly been on fungi in indoor air, in some fewer studies on bacterial genera. In this study, the focus is on bacterial species, and we show that occupants will be exposed to some of the same bacterial species at a daily level. The bacterial species found in the homes belong to genera which have previously been found in homes in other studies.

This study found a within-home variation (room-to-room) for concentrations of airborne bacteria. Thus, airborne bacterial concentrations were not uniform throughout the homes. This is in agreement with a study of homes in the United Kingdom. In spite of this, no significant variation was observed for the general room type except for a lower concentration in the basement. In a study from the USA, bacterial concentrations in the cellars were lower than in the bathrooms. In this study, there was a tendency towards the highest bacterial concentrations and humidity in the bathrooms. The lack of a general effect of room type for bacterial concentration is in accordance with what is found in Chinese homes. This indicates that the variation in exposure found between rooms may not be attributable to what the rooms, in general, are used for, or that it is also affected by other factors such as e.g. how much the windows are opened.

In this study, we have investigated whether concentrations of selected bacterial species (*Paracoccus yeei*, *Bacillus pumilus*, *Kocuria palustris*, *Kocuria rhizophila*, *Micrococcus luteus*, and *Micrococcus flavus*) seem to be affected by the factors: relative humidity, temperature, season, air change rate, and area per occupant. To our knowledge, this is the first study to investigate this. Other studies have investigated associations between bacteria considered as a unified group or staphylococci and the mentioned factor. In this study, we found that concentrations of some bacterial species decrease with increasing air change rate – this is in accordance with what is found for bacteria as a unified group and staphylococci. We found that concentrations of three bacterial species were highest when the indoor relative humidity was highest – in

studies of bacteria as a unified group, this association has not been found. This may be because different species have different preferences.

Type of paper: The paper is a research paper with measurements in 57 homes, and in 5 of the homes measurements have been done repeatedly throughout a year. Air samples taken in the homes have been analysed in the laboratory.

Yours sincerely, Anne Mette Madsen

Airborne bacterial species in indoor air and association with physical factors

Anne Mette Madsen^{a)*}, Saloomeh Moslehi-Jenabian^{a)}, Mika Frankel^{a)}, John Kerr White^{a,b)}, and Margit W. Frederiksen^{a)}

^{a)} National Research Centre for the Working Environment, Lersø Parkallé 105, 2100 Copenhagen Ø, Denmark; ^{b)} Division of Clinical Microbiology, Karolinska University Hospital, Stockholm, Sweden

*Corresponding author

Abstract

The aim of this study is to obtain knowledge about which cultivable bacterial species are present in indoor air in homes, and whether the concentration and species composition of airborne bacteria is associated with different factors. Measurements have been performed for one whole year inside different rooms in 5 homes and once in 52 homes. Within homes, a room-to-room variation for concentrations of airborne bacteria was found, but an overlap in bacterial species was found across rooms. Eleven species were found very commonly and included: *Acinetobacter lowffii*, *Bacillus megaterium*, *B. pumilus*, *Kocuria carniphila*, *K. palustris*, *K. rhizophila*, *Micrococcus flavus*, *M. luteus*, *Moraxella osloensis*, and *Paracoccus yeei*. The concentrations of gram-negative bacteria in general and the species *P. yeei* were significantly associated with the season with highest concentrations in spring. The concentrations of *P. yeei*, *K. rhizophila*, and *B. pumilus* were associated positively with relative humidity, and concentrations of *K. rhizophila* were associated negatively with temperature and air change rate. *Micrococcus flavus* concentrations were associated negatively with air change rate. Overall, this study identified species which are commonly present in indoor air in homes, and that the concentrations of some species were associated with the factors: season, air change rate, and relative humidity.

Key words: *Bacillus megaterium*, bacteria, exposure, home environment, indoor air, indoor humidity, MALDI-TOF MS, *Paracoccus yeei*, room-to-room variation, seasonality.

1. Introduction

Airborne bacteria in indoor environments are confirmed or presumed causal agents of various infectious diseases (1, 2). In addition, airborne bacteria are inflammogenic (3) and seem to be involved in either an increase or decrease in the risk of developing asthma and atopy (4, 5). Indoor work activities such as e.g. bed making (6, 7) can aerosolize bacteria, but whether concentrations of airborne bacteria in a home are related to room type is not clear. Concentrations of airborne bacteria are often higher in homes than in offices (8), and since the Covid-19 pandemic, more office work is occurring from homes. Generally, studies comparing the indoor and outdoor levels of bacteria have found that the indoor: outdoor ratios are above 1 (9-14).

Exposure assessment using personal samplers, e.g. the GSP (Gesamtstaubprobenahme), actively sampling airborne inhalable dust, is expected to be a good measure of personal exposure [19]. However, the sampling activity may interfere with everyday life in a home, due to e.g. noise of the sampling pump, and the necessity of the presence of a technician; thus only a few studies of this kind have been performed. Instead, bacteria in surface dust are studied, however the exact age of surface dust is unknown, and some of it may not have been airborne. Alternatively, the EDC (Electrostatic Dust Collector) sampling airborne dust by sedimentation on a cloth has been used in homes, offices, and social rooms at workplaces (15-19).

Air is an important transmission route for bacteria and therefore it is important to obtain knowledge about which bacteria are present in the indoor air and which factors affect this presence. In a review paper it is suggested that outdoor bacteria from plants may enter the building through ventilation systems, doors, windows, attached to people, pets, and other objects, and as a result, affecting the indoor concentration level – but also that information on these factors is still not well understood (20).

Potential health risks of bacteria are for many species evaluated at species level, and Matrix-assisted Laser Desorption Time of Flight (MALDI-TOF MS) is revealed as a reliable and useful method for identification of bacteria from the indoor environment (1, 17). Using MALDI-TOF MS for identification, it has been shown that the concentration of indoor *Staphylococcus* is associated with the indoor air change rate (ACR) and area per occupant indicating that it might be possible to affect the presence of *Staphylococcus* in indoor air (17). In contrast relative humidity (RH) of indoor air was not associated significantly with the concentration of viable bacteria in general (12) and with the commonly present genera *Staphylococcus*, *Bacillus*, *Kocuria*, and *Micrococcus* (17).

The aim of this study is to obtain knowledge about which bacterial species (non-*Staphylococcus* species) are present in indoor air in Danish homes, and whether the factors: season, ACR, RH, and occupants per area

affect the concentration of the most abundant bacterial species in living rooms. To obtain knowledge about whether the concentration of bacteria is related to room type we also study room-to-room variation.

2. Methodology

Study design

All homes were located in the Greater Copenhagen area. Sampling has been performed 6 or 7 times evenly distributed throughout one 1 year in five homes (called 1, 2, 3, 4, 5) in living rooms, bedrooms, and bathrooms, and in 3 homes also in the kitchens, and in two homes also in the basements using Gesamtstaubprobenahme samplers called GSPs (Study A, 127 samples). Homes 1 and 2 had pets; homes 1-4 had natural ventilation while home 5 had mechanical ventilation; home 4 had previously had moisture problems. In the same five homes sampling was also performed during each season in living rooms using EDCs (ZEEMAN, Alphen, Holland; Study B, 20 samples). In study C, EDC samples were taken in another 52 living rooms; these samples were taken in autumn, winter, or spring, with one sample per home. Dust samples and data on indoor: air change rate (ACR), Relative humidity (RH), and temperature as well as area per occupant are obtained from other studies (12, 17, 21).

Sampling and extraction

The GSPs were mounted with polycarbonate filters (37 mm, pore size 1.0 μm ; GE Water and Process Technologies, CO, USA), and they sampled airborne bacteria for 6 h from morning to afternoon. The EDC has a surface sampling area of 0.0209 m² (19 × 11 cm) and samples passively. The EDCs were placed on an open surface at 1.2-1.5 m above floor level, allowing dust to settle for 1 month. Extraction of dust from EDCs was carried out no later than 24 hours post-sample retrieval and extraction of dust from GSP filters no later than 2 hours post-sampling. Dust from EDC cloths and GSP filters was extracted according to our previous studies (12). Briefly, for EDC cloths 20.0 ml pyrogen-free water containing 0.85% NaCl and 0.05% Tween 80 was added to a 50 ml tube with one EDC cloth inside and the bacteria were extracted by orbital shaking (500 rpm) for 60 minutes. For the GSPs the filters were extracted in 5.0 ml of the same solution by orbital shaking (500 rpm) for 15 minutes, at room temperature. The suspension was harvested and an amount of 1.0 ml of the dust suspension was mixed with 0.5 ml glycerol and kept at – 80°C until they were plated on an agar medium.

Plating and identification of bacteria

An amount of 300 μl of each dust suspension from studies A and B was plated on nutrient agar plates (NA) and incubated at 25°C. From study C, an amount of 200 μl was plated on NA. All bacterial colonies were counted after 1 week of incubation. In study A, samples taken at the same time as the samples for study B were used for identification of bacteria (20 samples). Also from study A, samples from all rooms from a

summer sampling round were used for identification of bacteria (18 samples). From study B (20 samples) and study C (52 samples), bacteria in all samples were identified.

Bacterial isolates were identified by matrix-assisted laser desorption-ionisation time-of-flight (MALDI-TOF) mass spectrometry (MS) by using a Microflex LT mass spectrometer (Bruker Daltonics, Germany). A bacterial test standard (Bruker Daltonics) was used to calibrate the instrument, following the guidelines of the manufacturer. Spectra were analysed using Bruker Biotyper 3.1 software. Bacterial isolates were prepared using the extended direct transfer method (22).

Data treatment

Bacterial concentrations were calculated as time-weighted average (TWA). The room-to-room variations are presented as geometric mean (GM) values with confidence limits. The species from EDCs are presented as colony forming units (CFU) of the species/m²/day and GSP data as CFU of the specific species or genera/m³ air. Room-to-room variation in bacterial concentrations, Rh, and temperature within homes was analysed using GLIMIX with random effects of season, sampling day, and home, and General linear models (GLM). The association between bacterial concentrations (Study A and B), ACR, RH, temperature, and season were calculated using GLIMIX with random effect of home. Microbial diversity analyses were performed in Rstudio version 3.5.3 using the R CRAN package *vegan*. Comparisons of microbial diversity between seasons were performed using the analysis of similarity (ANOSIM) function according to Jaccard index values (23). The association between bacterial concentrations (Study C), ACR, area per occupant, RH, temperature, and season were also calculated using GLIMIX. These analysis were done in SAS version 9.4. The most dominating species in terms of bacterial concentration are presented as relative concentrations. Only data on species other than *Staphylococcus* are part of this study.

3. Results

Room-to-room variation

The GM concentrations of bacteria were across rooms and homes 519 CFU/m³ [253, 1063]. A room-to-room variation within the five homes was found if data were analysed unaffected by home ($p=0.0089$) with lowest bacterial concentrations in the cellars (**Table 1**), and when analysed with random effects of season and home ($p<0.0001$). In home 1, a high bacterial concentration was found in the bathroom. The temperature ($p<0.0001$) and relative humidity ($p=0.0003$) were different in the different room types. Thus temperature was lower in the basements and bedrooms than in the other rooms. The RH was higher in the bathrooms ($p=0.016$) and basement ($p=0.025$) than in the living rooms while the kitchens tended to have lower RH than the living rooms ($p=0.064$).

Table 1. Concentrations of bacteria (GM, CFU/m³) in different rooms in homes 1-5.


Rooms	Across homes CFU/m ³			Within homes CFU/m ³				
	n ¹⁾	GM	CI ²⁾	1	2	3	4	5
Bathroom	34	761 ^{a 3)}	[417, 1386]	1088 ^a	695 ^a	389 ^a	2479 ^a	414 ^{ab}
Basement	13	144 ^b	[62, 336]	-	98 ^b	-	225 ^b	-
Bedroom	34	746 ^a	[366, 1520]	609 ^b	433 ^{ab}	700 ^a	2047 ^a	706 ^a
Kitchen	13	279 ^a	[118, 662]	478 ^b	-	176 ^a	-	-
Living room	33	509 ^a	[278, 934]	309 ^b	1015 ^a	273 ^a	1469 ^a	295 ^b
P-values ⁴⁾		<0.0001		0.078	0.0038	0.23	0.019	0.087

¹⁾n=numbers of samples, ²⁾CI=confidence limit. ³⁾Numbers in the same column followed by the same letter are not significantly different. ⁴⁾P-values for comparisons of bacterial concentrations between room types.

In one summer sampling round, the bacteria from the different rooms were identified. The three bacterial species found in the highest concentrations in all rooms were the same within the same home; in all homes, *Micrococcus luteus* was among these three species. Other dominating species are mentioned in brackets (Home 1: *Shingomonas aerolata* and *Lysinibacillus*; Home 2: *Bacillus licheniformis* and *Arthrobacter sulfonivorans*; Home 3: *Moraxella osloensis* and *Paracoccus yeei*; Home 4: *Kocuria palustris* and *K. rhizophila*; Home 5: *Moraxella osloensis* and *P. yeei*).

Bacterial species in living rooms

Bacteria were identified in one sample per season in the living rooms of the five homes (Study A). Some species were observed frequently, but in low concentrations, e.g. *Mo. osloensis*, while other species e.g. *B. megaterium* and *Paenibacillus glucanolyticus* were observed seldom but when observed they were present in high concentrations. The gram-negative bacterium *P. yeei* was observed repeatedly, and it constituted a large part of the airborne gram-negative bacteria (**Fig. 1a**). Fourteen different *Bacillus* species were found (**Fig. 1b**). Of gram-positive bacteria (other than *Bacillus* species) the species *K. rhizophila* was found in many samples and in high concentrations (**Fig. 1c**).






Fig. 1 abc. Gram-negative bacteria (a), the fourteen *Bacillus* species (b), and gram-positive bacteria other than *Bacillus* and *Staphylococcus* (c) found in the living rooms of the five homes with one sample from each season (Study A); all presented as % of total isolates within the category.

To see whether there is an overlap in bacterial species as sampled using GSPs during one day each season (Study A) versus using EDC samplers for long-term sampling (study B) the bacterial species found in the highest concentrations in the five homes are presented in a Venn diagram and an overlap in species is found (**Fig. 2**). In addition, irrespectively of whether samples were taken using an EDC or GSP sampler, the microbial diversity and abundance varied based on seasonality with especially winter being different (ANOSIM, $p = 0.007$).

To get an impression of bacterial species in living rooms of Danish city homes in general, 52 samples taken using EDCs were screened for bacterial species (study C), and the 25 species found in highest concentrations are presented in the Venn diagram. Eleven species were found in high concentrations in the living rooms of the five homes unaffected by the sampling method and in the 52 homes (**Fig. 2**). A list of species found in more than one home can be found in Table s1.




Fig. 2. The 25 dominating bacterial species in samples from the living room in 5 homes with repeated measurements using GSPs (A) for sampling once per season using EDCs (B), and once in the living room of 52 homes using EDCs (C). The A, B, and Cs following some bacterial names indicate that the bacterium has also been found in study A, B, or C – but not among the 25 dominating species, and the symbol ‘-’ indicates that the bacterium is Gram-negative.

Concentrations of selected bacterial species as affected by indoor physical factors

For some of the species we have found most frequently and for gram-negative species considered together, we have studied factors which may affect the measured concentration. Associations with P-values < 0.1 are considered significant. In study A, the concentration of gram-negative bacteria as measured using the GSP samplers was affected by season ($p=0.0016$) with lower concentrations in summer than in winter. The concentration of *P. yeei* tended to be associated negatively with increasing temperature and was affected by the season with the highest concentrations in spring. *Micrococcus flavus* was associated negatively with ACR and *B. pumilus* positively with RH. *Kocuria rhizophila* was associated positively with RH and negatively with temperature and ACR (Table 2).

Table 2. Associations between concentrations of airborne bacteria as measured using GSP samplers repeatedly in the living room of five homes, and ACR, RH, temperature, and season (Study A).

Fixed factor	<i>Paracoccus yeii</i>		<i>Bacillus pumilus</i>		<i>Kocuria palustris</i>		<i>Kocuria rhizophila</i>		<i>Micrococcus luteus</i>		<i>Micrococcus flavus</i>	
	Estimate	p-value ¹⁾	Estimate	p-value	Estimate	p-value	Estimate	p-value	Estimate	p-value	Estimate	p-value
Each factor studied separately												
ACR	-0.41	0.39	-0.24	0.40	-0.14	0.52	-0.37	0.091	-0.26	0.12	-0.48	0.059
RH	2.40	0.52	6.78	0.0002	5.21	0.096	7.44	0.022	-0.17	0.94	-0.26	0.95
Temperature	-5.56	0.15	-0.046	0.31	-0.12	0.048	-0.14	0.051	-0.0075	0.11	-0.017	0.84
Season ³⁾	-	0.081	-	0.0045	-	0.019	-	0.069	-	0.077	-	0.63
Spring	1.46	0.042	0.060	0.85	-0.27	0.59	-0.40	0.52	0.49	0.26	0.10	0.90
Summer	-0.25	0.70	0.060	0.85	-0.50	0.34	-0.71	0.26	-0.58	0.18	-0.75	0.37
Autumn	0.18	0.78	1.19	0.0019	1.21	0.031	0.98	0.13	0.42	0.34	0.22	0.79
Winter	reference		Reference		Reference		reference		reference		reference	
Stepwise regression²⁾												
ACR	-	-	-	-	-	-	-0.51	0.0059	-	-	-0.48	0.059
RH	8.85	0.064	6.78	0.0002	-	-	8.70	0.0025	-	-	-	-
Temperature	-	-	-	-	-	-	-	-	-	-	-	-
Season	-	0.036	-	-	-	0.019	-	-	-	-	-	-
Spring	1.54	0.034	-	-	-	-	-	-	-	-	-	-
Summer	-	-	-	-	-	-	-	-	-	-	-	-
Autumn	-	-	-	-	1.21	0.031	-	-	-	-	-	-
Winter	reference		Reference		Reference		Reference		Reference		Reference	

¹⁾ P-values below 0.1 are in bold; concentrations are compared using the GLIMMIX procedure with Poisson distributed data; estimates (β -coefficients) are presented. ²⁾ Statistically significant factors in the stepwise regression with backward regression. ³⁾ Relative to winter. ACR=air change rate; RH=relative humidity.

In study B, *K. rhizophila* was associated negatively with temperature ($\beta=-10.0$, $p=0.031$); other associations were not significant. In the cross-sectional study (study C), associations were found between area per occupant and *K. palustris* concentration ($\beta=-1.6$, $p=0.091$), and temperature and *M. flavus* concentration ($\beta=-21$, $p=0.079$).

4. Discussion

In this study, we show that cultivable *K. palustris*, *K. rhizophila*, *M. luteus*, *M. flavus*, *B. pumilus*, *K. megaterium*, *K. carniphila*, *Acinetobacter lowffii*, *Mo. osloensis*, and *P. yeii* are common in indoor air in homes in Greater Copenhagen, in addition to the previously found *Staphylococcus* species (17). These results were unaffected by the sampling method stable. Thus, people seem to be exposed to these bacteria via inhalation on daily basis.

Some of the found species are classified as risk class 2 pathogens e.g. *P. yeii* which has caused e.g. keratitis and conjunctivitis (24, 25) and *B. cereus* which is a food-poisoning agent (26). Some are described as opportunistic pathogens, e.g. *Mo. osloensis* (e.g. in the airways of an elderly patient (27)) and *Rhizobium radiobacter* (e.g. pneumonia in a cancer patient (28)). *Kocuria* species are described as emerging human pathogens (29). An underlying mechanism explaining many health effects of exposure to airborne particles is the ability to induce the formation of reactive oxygen species (ROS) within the airways. There is limited

knowledge on the ability of different species to induce ROS production (without infection), but few studies indicate differences at the species level (30, 31).

Many of the found species have previously been found in quite different environments. The bacteria found in high concentrations, *P. yeii*, *B. megatarium*, and *M. luteus*, have previously been found on indoor surfaces (32, 33), but also as airborne bacteria in totally other environments such as wastewater treatment plants (34), pigeon coops (35), and on workers' clothes (36). We have found many different *Bacillus* species and a high species richness of *Bacillus* has also been found in air samples from different occupational settings (35, 37) as well as on indoor surfaces (32). When considering the bacteria at the genus level the genera *Kocuria*, *Micrococcus*, *Bacillus*, and *Paenibacillus* were among the dominating, and these genera were also dominating in indoor air in Hong Kong and China (reviewed in (20)).

This study found a within-home variation (room-to-room) for concentrations of airborne bacteria. Thus, airborne bacterial concentrations were not uniform throughout the homes during the time of sampling, which is in agreement with a study in homes in the United Kingdom (38). In spite of this, no significant variation was observed for general room type (e.g. bathroom vs. living room) except for a lower concentration in the basement. Furthermore, the same bacterial species were found in the highest concentrations in all rooms within the same home. In a study from the USA, bacterial concentrations in the cellars were lower than in the bathrooms, while cellars, kitchens, and bedrooms did not differ significantly (14). In this study, there was a tendency towards the highest bacterial concentrations and humidity in the bathrooms, while the bedrooms also had high bacterial concentrations but low temperatures. The lack of a general effect of room type for bacterial concentration is in accordance with what is found in Chinese homes (39). This indicates on one hand that the variation in exposure found between rooms may not be attributable to what the rooms in general are used for, or that it is also affected by other factors as e.g. ACR. In this study, the repeated sampling using GSP samplers in the five homes was done in the daytime while the occupants mainly were not at home. Previous studies have shown that bacterial concentrations in indoor air are higher in presence of occupants (21).

For some bacterial species, associations between concentrations in living rooms and seasons were found. Thus *Paracoccus yeii* was found in the highest concentrations in the spring. The habitat of *P. yeii* seems not to be well characterized, and in research papers, it is mainly described concerning infections. Thus we do not know the source of exposure to this bacterium. *Paracoccus yeii* is a gram-negative bacterium, and for gram-negative bacteria in general lower concentrations were found in summer than in winter. This may be related to the impact of UV light on bacterial survival.

The two species *B. pumilus* and *K. palustris* were found in the highest concentrations in autumn. These bacteria have previously been found in soil. At the genus level, we have previously observed that *Kocuria* is present in the lowest concentrations in summer (17). *Kocuria palustris*, *K. rhizophila*, and *M. flavus* were associated negatively with indoor temperature. For the two *Kocuria* species, this is in accordance with what has previously

been found for the genus and in contrast to what is found for the genus *Staphylococcus* (17) and bacteria in general in Greek homes (40).

Human skin is shed into the indoor air (41), and therefore it could be expected that the concentration of skin-related bacterial species is negatively associated with ACR. The two species *K. rhizophila* and *M. flavus* were associated negatively with ACR and thus seem not to enter by open windows or ventilation systems. These species are not described as skin-related bacteria, but *K. rhizophila* has been found on the skin (42). Another transmission route to the home environment may be clothing and in particular work clothing from environments with high exposure to bacteria. Thus a recent study has shown that bacteria accumulate on work clothing in high amounts during a workday and that bacteria may be released from the clothes to the home air; in fact, cultivable *K. rhizophila* has been found on work clothes together with more than 200 different cultivable bacterial species (36, 43). In study C, the *K. palustris* concentration was associated negatively with area per occupant. Therefore, it may also have human or human activity as source. The habitats of this species are not well described, but it has been isolated from very different environments including human skin (44), workers' hands (22), human noses (45), and marine algae (46). In a study about bacterial genera in outdoor air, *Bacillus* and *Acinetobacter* but not *Kocuria* were among the most frequently found genera (47).

Micrococcus luteus was very common in indoor air in this study, and it is described as a skin-related bacterium. Despite that, it was not associated significantly with ACR or area per occupant. Furthermore, the species did not show seasonality. The lack of association between the studied factors and concentrations of *M. luteus* might be because this species has several sources as it is found both in soil, dust (48), airways, and human skin (49). It has also been found in school air (48) in the air and on hand palms in occupational settings (22).

5. Conclusion

Across homes and room types within homes, occupants are exposed to some of the same cultivable bacterial species typically including: *K. palustris*, *K. rhizophila*, *M. luteus*, *M. flavus*, *B. pumilus*, *B. megaterium*, *K. carniphila*, *Acinetobacter lowffii*, *Mo. osloensis*, and *P. yeei*. Concentrations of *P. yeei* were associated significantly with the season. Bacterial concentrations were not uniform throughout the homes, but no significant variation was observed for the general room type except for the lower concentration in the basements. The concentrations of *P. yeei*, *K. rhizophila*, and *B. pumilus* were associated positively with relative humidity, and concentrations of *K. rhizophila* were associated negatively with temperature while *K. rhizophila* and *M. flavus* were associated negatively with air change rate, and *K. palustris* negatively with area per occupant. Thus decreasing the relative humidity, and increasing the air change rate and area per occupant might be a strategy to reduce the exposure to some airborne bacterial species.

Funding and Acknowledgement statements

This study was funded by Grundejernes Investeringsfund (GI).

Authorship Contribution

Anne Mette Madsen: Conceptualization, Methodology, Formal analysis, Writing - Original Draft, Supervision.
Saloomeh Moslehi-Jenabian: Formal analysis, Investigation, Data Curation, Writing - Original Draft. Mika Frankel:
Formal analysis, Investigation, Data Curation. John Kerr White: Formal analysis. Margit W. Frederiksen: Formal
analysis, Investigation, Data Curation

Conflicts of Interest

No conflicts of interest

Ethics Approval

This study requires no ethical approval.

Data availability statement

The datasets generated during and/or analysed during the current study are available from the corresponding author on reasonable request.

References

1. Mkrtychyan HV, Russell CA, Wang N, Cutler RR. 2013. Could public restrooms be an environment for bacterial resistomes? *PLoS one* 8: e54223
2. Perkins SD, Angenent LT. 2010. Potential pathogenic bacteria in metalworking fluids and aerosols from a machining facility. *FEMS microbiology ecology* 74: 643-54
3. Atosuo J, Karhuvaara O, Suominen E, Vilén L, Nuutila J, Putus T. 2021. Indoor-related microbe damage induces complement system activation in building users. *Innate Immunity* 27: 15-22
4. Ege MJ, Mayer M, Normand A-C, Genuneit J, Cookson WO, Braun-Fahrlander C, Heederik D, Piarroux R, von Mutius E. 2011. Exposure to environmental microorganisms and childhood asthma. *New England Journal of Medicine* 364: 701-9
5. Brooks C, Pearce N, Douwes J. 2013. The hygiene hypothesis in allergy and asthma: an update. *Current opinion in allergy clinical immunology* 13: 70-7
6. Overton E. 1987. The Journal of Infection Control, Nursing. Bed-making and bacteria. *Nursing times* 84: 69-71
7. Balasubramanian R, Nainar P, Rajasekar A. 2012. Airborne bacteria, fungi, and endotoxin levels in residential microenvironments: a case study. *Aerobiologia* 28: 375-90
8. Gorny RL, Dutkiewicz J. 2002. Bacterial and fungal aerosols in indoor environment in Central and Eastern European countries. *Ann. Agric. Environ Med* 9: 17-23
9. Bartlett KH, Kennedy SM, Brauer M, van NC, Dill B. 2004. Evaluation and a predictive model of airborne fungal concentrations in school classrooms. *Ann. Occup Hyg* 48: 547-54
10. Scheff PA, Paulius VK, Curtis L, Conroy LM. 2000. Indoor air quality in a middle school, Part II: Development of emission factors for particulate matter and bioaerosols. *Applied Occupational and Environmental Hygiene* 15: 835-42
11. Kalogerakis N, Paschali D, Lekaditis V, Pantidou A, Eleftheriadis K, Lazaridis M. 2005. Indoor air quality–bioaerosol measurements in domestic and office premises. *Journal of Aerosol Science* 36: 751-61
12. Frankel M, Beko G, Timm M, Gustavsen S, Hansen EW, Madsen AM. 2012. Seasonal variation of indoor microbial exposures and their relations to temperature, relative humidity and air exchange rates. *Applied and Environmental Microbiology* 78: 8289-97
13. Adhikari A, Lewis JS, Reponen T, Degraesse EC, Grimsley LF, Chew GL, Iossifova Y, Grinshpun SA. 2010. Exposure matrices of endotoxin, (1→3)-beta-d-glucan, fungi, and dust mite allergens in flood-affected homes of New Orleans. *Science of the Total Environment* 408: 5489-98
14. Moschandreas D, Pagilla KR, Storino LV. 2003. Time and Space Uniformity of Indoor Bacteria Concentrations in Chicago Area Residences. *Aerosol Science and Technology* 37: 899-906
15. Frankel M, Timm M, Hansen EW, Madsen AM. 2012. Comparison of sampling methods for assessment of indoor microbial exposure. *Indoor Air* 22: 405-14

16. Noss I, Wouters IM, Visser M, Heederik DJ, Thorne PS, Brunekreef B, Doekes G. 2008. Evaluation of a low-cost electrostatic dust fall collector for indoor air endotoxin exposure assessment. *Appl. Environ Microbiol* 74: 5621-7
17. Madsen AM, Moslehi-Jenabian S, Islam MZ, Frankel M, Spilak M, Frederiksen MW. 2018. Concentrations of *Staphylococcus* species in indoor air as associated with other bacteria, season, relative humidity, air change rate, and *S. aureus*-positive occupants. *Environ Res* 160: 282-91
18. Liebers V, van K, V, Bungler J, Duser M, Stubel H, Bruning T, Raulf-Heimsoth M. 2012. Assessment of Airborne Exposure to Endotoxin and Pyrogenic Active Dust Using Electrostatic Dustfall Collectors (EDCs). *J Toxicol Environ Health A* 75: 501-7
19. Rocchi S, Reboux G, Frossard V, Scherer E, Valot B, Laboissière A, Zaros C, Vacheyrou M, Gillet F, Roussel SJSotTE. 2015. Microbiological characterization of 3193 French dwellings of Elfe cohort children. 505: 1026-35
20. Guo K, Qian H, Zhao D, Ye J, Zhang Y, Kan H, Zhao Z, Deng F, Huang C, Zhao B. 2020. Indoor exposure levels of bacteria and fungi in residences, schools, and offices in China: A systematic review. *Indoor air* 30: 1147-65
21. Madsen AM, Matthiesen CB, Frederiksen MW, Frederiksen M, Frankel M, Spilak M, Gunnarsen L, Timm M. 2012. Sampling, extraction and measurement of bacteria, endotoxin, fungi and inflammatory potential of settling indoor dust. *Journal of Environmental Monitoring* 14: 3230-9
22. Madsen AM, Frederiksen MW, Jacobsen MH, Tendal K. 2020. Towards a risk evaluation of workers' exposure to handborne and airborne microbial species as exemplified with waste collection workers. *Environmental Research* 183: 109177
23. Jari Oksanen F, Friendly M, Kindt R, Legendre P, McGlinn D, Minchin PR, O'Hara R, Simpson GL, Solymos P, Stevens MHHJRpv. 2018. Vegan: community ecology package. 2
24. Courjaret J-C, Drancourt M, Hoffart LJE, Lens C. 2014. Paracoccus yeei keratitis in a contact lens wearer. 40: e21-e2
25. Ufford I, Caines J, Haigh H, Wilson C. 2015. PARACOCUS YEEI SPECIES CAUSING BACTERIAL CONJUNCTIVITIS WITH CELLULITIS. *Medical Research Archives* 3: 1-4
26. Unfallversicherung IfAdDG. 2017. Gestis - Internationale Grenzwerte für chemische Substanzen. In <http://www.dguv.de/ifa/gestis/gestis-internationale-grenzwerte-fuer-chemische-substanzen-limit-values-for-chemical-agents/index.jsp>
27. Gargiulo C, Pham V, Hai N, Nguyen K, Davey K, Abe K. 2015. A case report of an elderly patient with respiratory failure caused by Moraxella osloensis infection. *Anaesthesia* 1: 17-21
28. Lai C-C, Teng L-J, Hsueh P-R, Yuan A, Tsai K-C, Tang J-L, Tien H-F. 2004. Clinical and microbiological characteristics of Rhizobium radiobacter infections. *Clinical infectious diseases* 38: 149-53
29. Kandi V, Palange P, Vaish R, Bhatti AB, Kale V, Kandi MR, Bhoomagiri MR. 2016. Emerging bacterial infection: identification and clinical significance of Kocuria species. *Cureus* 8: 1-6
30. Samake A, Uzu G, Martins J, Calas A, Vince E, Parat S, Jaffrezo J. 2017. The unexpected role of bioaerosols in the Oxidative Potential of PM. *Scientific reports* 7: 10978
31. Hirvonen MR, Huttunen K, Roponen M. 2005. Bacterial strains from moldy buildings are highly potent inducers of inflammatory and cytotoxic effects. *Indoor Air* 15 Suppl 9: 65-70
32. Madsen AM, Phan HU, Laursen M, White JK, Uhrbrand K. 2020. Evaluation of methods for sampling of Staphylococcus aureus and other Staphylococcus species from indoor surfaces. *Annals of Work Exposures and Health* 64: 1020-34
33. Bae IK, Kang DH, Kim SM, Bae YM. 2017. Distribution and Identification of Gram-Negative Bacteria in Indoor Environment of Houses. *Journal of Korean Society of Oral Health Science* 1: 58-62
34. Lu R, Frederiksen MW, Uhrbrand K, Li Y, Østergaard C, Madsen AM, Safety E. 2020. Wastewater treatment plant workers' exposure and methods for risk evaluation of their exposure. *J Ecotoxicology* 205: 111365
35. Madsen AM, White JK, Nielsen JL, Keskin ME, Tendal K, Frederiksen MWJER. 2022. A cross sectional study on airborne inhalable microorganisms, endotoxin, and particles in pigeon coops—Risk assessment of exposure. 204: 112404
36. Madsen AM, Rasmussen PU, Frederiksen MW. 2022. Accumulation of microorganisms on work clothes of workers collecting different types of waste—A feasibility study. *Waste Management* 139: 250-7
37. Madsen AM, White JK, Markouch A, Kadhim S, de Jonge N, Thilsing T, Hansen VM, Bælum J, Nielsen JL, Vogel U. 2020. A cohort study of cucumber greenhouse workers' exposure to microorganisms as measured using NGS and MALDI-TOF MS and biomarkers of systemic inflammation. *Environmental Research* 192: doi.org/10.1016/j.envres.2020.110325

38. Nasir ZA, Colbeck I. 2012. Winter time concentrations and size distribution of bioaerosols in different residential settings in the UK. *Water, Air, Soil Pollution* 223: 5613-22
39. Ye J, Qian H, Zhang J, Sun F, Zhuge Y, Zheng X. 2021. Combining culturing and 16S rDNA sequencing to reveal seasonal and room variations of household airborne bacteria and correlative environmental factors in nanjing, southeast china. *Indoor air* 31: 1095-108
40. Stamatelopoulou A, Pyrri I, Asimakopoulos D, Maggos T. 2020. Indoor air quality and dustborne biocontaminants in bedrooms of toddlers in Athens, Greece. *Building Environment International* 173: 106756
41. Noble WC, Habbema JD, van FR, Smith I, de RC. 1976. Quantitative studies on the dispersal of skin bacteria into the air. *Journal of medical microbiology* 9: 53-61
42. Hillion M, Mijouin L, Jaouen T, Barreau M, Meunier P, Lefeuvre L, Lati E, Chevalier S, Feuilloley MG. 2013. Comparative study of normal and sensitive skin aerobic bacterial populations. *Microbiologyopen* 2: 953-61
43. Møller SA, Rasmussen PU, Frederiksen MW, Madsen AM. 2022. Work clothes as a vector for microorganisms: Accumulation, transport, and resuspension of microorganisms as demonstrated for waste collection workers. *Environment International* 161
44. Al Bayatee MA, Alsammak EG. 2018. Phenetic and Phylogenetic Analysis of *Kocuria palustris* and *Kocuria rhizophila* Strains isolated from Healthy and Thalassemia Persons. *SCIENTIFIC JOURNAL OF MEDICAL RESEARCH* 2: 135-46
45. Kaspar U, Kriegeskorte A, Schubert T, Peters G, Rudack C, Pieper DH, WoσGÇÉOxley M, Becker K. 2016. The culturome of the human nose habitats reveals individual bacterial fingerprint patterns. *Environmental Microbiology* 18: 2130-42
46. Leiva S, Alvarado P, Huang Y, Wang J, Garrido I. 2015. Diversity of pigmented Gram-positive bacteria associated with marine macroalgae from Antarctica. *FEMS Microbiology Letters* 362
47. Fykse EM, Tjærnhage T, Humppi T, Eggen VS, Ingebretsen A, Skogan G, Olofsson G, Wästerby P, Gradmark P-Å, Larsson AJA. 2015. Identification of airborne bacteria by 16S rDNA sequencing, MALDI-TOF MS and the MIDI microbial identification system. 31: 271-81
48. Fox K, Fox A, Elssner T, Feigley C, Salzberg D. 2010. MALDI-TOF mass spectrometry speciation of staphylococci and their discrimination from micrococci isolated from indoor air of schoolrooms. *Journal of Environmental Monitoring* 12: 917-23
49. Kloos WE, Musselwhite MS. 1975. Distribution and persistence of *Staphylococcus* and *Micrococcus* species and other aerobic bacteria on human skin. *Applied Microbiology* 30: 381-95

Supplementary file 1

Airborne bacterial species in indoor air and association with physical factors

Anne Mette Madsen^{a)*}, Salomeh Moslehi-Jenabian^{a)}, Mika Frankel^{a)}, John Kerr White^{a,b)}, and Margit W. Frederiksen^{a)}

a) National Research Centre for the Working Environment, Lersø Parkallé 105, 2100 Copenhagen Ø, Denmark;

b) Division of Clinical Microbiology, Karolinska University Hospital, Stockholm, Sweden

Table s1. Bacterial species found in more than one of 57 homes.

<i>Acinetobacter lwoffii</i>	<i>Brevibacterium casei</i>	<i>Micrococcus luteus</i>
<i>Acinetobacter schindleri</i>	<i>Brevibacterium iodinum</i>	<i>Micrococcus terreus</i>
<i>Acinetobacter townneri</i>	<i>Brevundimonas sp</i>	<i>Moraxella osloensis</i>
<i>Aerococcus viridans</i>	<i>Cellulosimicrobium cellulans</i>	<i>Mycoplasma hyorhinis</i>
<i>Arthrobacter oxydans</i>	<i>Corynebacterium afermentans</i>	<i>Paenibacillus amylolyticus</i>
<i>Arthrobacter polychromogenes</i>	<i>Corynebacterium lipophiloflavum</i>	<i>Paenibacillus anaericanus</i>
<i>Arthrobacter stackebrandtii</i>	<i>Corynebacterium sanguinis</i>	<i>Paenibacillus borealis</i>
<i>Arthrobacter sulfonivorans</i>	<i>Curtobacterium flaccumfaciens</i>	<i>Paenibacillus cookii</i>
<i>Bacillus altitudinis</i>	<i>Dermacoccus nishinomiyaensis</i>	<i>Paenibacillus glucanolyticus</i>
<i>Bacillus amyloliquefaciens</i>	<i>Dermacoccus sp</i>	<i>Paenibacillus pabuli</i>
<i>Bacillus arsenicus</i>	<i>Dietzia cinnamea</i>	<i>Paenibacillus polymyxa</i>
<i>Bacillus badius</i>	<i>Dietzia papillomatosis</i>	<i>Pantoea sp</i>
<i>Bacillus cereus</i>	<i>Enterococcus casseliflavus</i>	<i>Paracoccus sp.</i>
<i>Bacillus clausii</i>	<i>Filifactor villosus</i>	<i>Paracoccus yeei</i>
<i>Bacillus firmus</i>	<i>Gordonia rubripertincta</i>	<i>Penicillium brevicompactum</i>
<i>Bacillus flexus</i>	<i>Halomonas elongata</i>	<i>Pseudomonas fulva</i>
<i>Bacillus indicus</i>	<i>Jeotgalicoccus halotolerans</i>	<i>Pseudomonas oryzihabitans</i>
<i>Bacillus iodinum</i>	<i>Kocuria carniphila</i>	<i>Pseudomonas stutzeri</i>
<i>Bacillus licheniformis</i>	<i>Kocuria marina</i>	<i>Psychrobacillus</i>
<i>Bacillus megaterium</i>	<i>Kocuria palustris</i>	<i>Psychrobacillus psychrotolerans</i>
<i>Bacillus muralis</i>	<i>Kocuria rhizophila</i>	<i>Rhizobium radiobacter</i>
<i>Bacillus mycoides</i>	<i>Kocuria sp.</i>	<i>Rhodococcus corynebacterioides</i>
<i>Bacillus psychrosaccharolyticus</i>	<i>Kocuria varians</i>	<i>Rhodococcus erythropolis</i>
<i>Bacillus pumilus</i>	<i>Kytococcus schroeteri</i>	<i>Rhodococcus kroppenstedtii</i>
<i>Bacillus simplex</i>	<i>Kytococcus sedentarius</i>	<i>Roseomonas mucosa</i>
<i>Bacillus subtilis</i>	<i>Lactobacillus sakei</i>	<i>Rothia amarae</i>
<i>Bacillus vallismortis</i>	<i>Lysinibacillus fusiformis</i>	<i>Solibacillus silvestris</i>
<i>Bacillus weihenstephanensis</i>	<i>Lysinibacillus sphaericus</i>	<i>Sphingomonas desiccabilis</i>
<i>Bacillus licheniformis</i>	<i>Macrococcus caseolyticus</i>	<i>Spingomonas faeni</i>
<i>Bacillus subtilis</i>	<i>Massilia timonae</i>	<i>Sporosarcina psychrophila</i>
<i>Bacilluspsychrosaccharolyticus</i>	<i>Microbacterium oxydans</i>	<i>Springmonas sp.</i>
<i>Brachybacterium faecium</i>	<i>Microbacterium paraoxydans</i>	<i>Streptomyces badius</i>
<i>Brevibacillus agri</i>	<i>Micrococcus flavus</i>	<i>streptomyces griseus</i>
		<i>Streptomyces violaceoruber</i>